

ADDENDUM #2

Project Name: Football Field Renovations at John B. Connally, Anson Jones, E.M. Pease, and H.B. Zachry Middle Schools
RFCSP# 2021-011

Addendum Number: Two (2)

Addendum Date: April 8, 2021

Addendum Description: This addendum modifies, amends, or replaces the Proposal Documents dated March 19, 2021 as follows. Modifications, amendments, or replacements described here shall be considered part of the Contract Documents as fully and as completely as though the same was included therein.

This addendum does not modify the bid date.

Contractor Questions: Questions from prospective bidders which were received via email have been answered and included with this addendum.

Specifications: None

Drawings: None

Addendum Acknowledgment: Bidder shall acknowledge receipt of this addendum on the Proposal Form, and agrees that modifications, amendments, or replacements described here are reflected in Proposer's pricing proposal.

-- END OF ADDENDUM --

Contractor Questions

Q1: Can you provide the model # or spec for the “new bleachers” that are to be installed?

A1: The angle frame aluminum bleachers detailed on Sheet C5.11 are typical to several manufacturers. The detail was supplied by Sturdisteel.

NISD Pre-Approved Bleacher Manufacturers:

1. Southern Bleacher Company, P.O. Box One, Graham, TX 76450. 1.800.433.0912, fax: 1.940.549.1365. www.southernbleacher.com.

2. Sturdisteel Company, POB 2655, Waco TX 76702, (800) 433-3116; Fax (254) 666-4472. www.sturdisteel.com

3. Dant Clayton Corporation, 1500 Bernheim Lane, Louisville, KY 40210, (502) 634-3626. www.stadiumbleachers.com

Q2: On sheet – L4.04 at Zachry Middle school: Are we to provide a new water meter, backflow preventer and master valve? It’s not shown on civil plan. Can you clarify?

A2: No. A new irrigation meter and backflow preventer is to be installed under a different project. This project ties into that proposed new service.